

ADDENDUM #1
Complete Distribution Systems Material Inventories
Charter Township of Grand Blanc
May 1, 2024

The following clarifications and additions are to be incorporated into the construction plans, bidding and contract documents:

1. Question: I see that there are 331 water heads to be replaced. We are a hydro vac company. Do we need someone with a plumber's license to replace these? I'm not sure we are qualified for this bid if that is the case.

Response: No, a plumber's license is not required to replace the water service boxes.

2. Question: On page 340 of the spec, for the schematic of the curb box, there is a note that says "No Taps, services or fixtures (curb box, valves, manholes, hydrants, etc.) will be permitted in/under a driveway or sidewalk area" - If we come across an existing curb stop in a driveway / pavement are we responsible for performing the inspection and changing the curb box, or will these locations be skipped?

Response: We will skip curb boxes in pavement areas and add the next service on the CDSMI Service List in order. A total of 331 water service investigations must be completed.

3. Question: Is it anticipated that we will be replacing all 331 curb boxes, or only ones that appear damaged/old? - if it is anticipated to be less than the total 331, can the quantities on the bid form be adjusted to be more in line with the expected work?

Response: We intend on replacing all the curb boxes.

Each bidder must acknowledge receipt of this addendum of the Bid Section C-410 Article 5.03.A.

END OF ADDENDUM

Prepared by:
ROWE Professional Services Company
540 S. Saginaw Street
Suite 200
Flint, MI 48502
(810) 341-7500