

ADDENDUM #1
Water System Improvements – Proposed Booster Pump Station
Village of Port Sanilac
April 11, 2024

The following clarifications and additions are to be incorporated into the construction plans, bidding and contract documents:

Sheet M-3 Modification:

Air Damper AD-1 and AD-2 shall be model VCD-23 with 22-2FER-2 drive and a Belimo TFB24-S damper activator or approved equal.

Each bidder must acknowledge receipt of this addendum of the Bid Section C-410 Article 7.03.A.

END OF ADDENDUM

Prepared by:
ROWE Professional Services Company
540 S. Saginaw Street
Suite 200
Flint, MI 48502
(810) 341-7500